

J. Bernie Beasley, Jr., P.E.
Vice President

Southern Nuclear
Operating Company, Inc.
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201

Tel 205 992 7110
Fax 205 992 0403



October 8, 2002

Docket No. 50-364

NEL-02-0204

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Joseph M. Farley Nuclear Plant – Unit 2
Steam Generator Plugging 15-Day Report

Ladies and Gentlemen:


In accordance with Technical Specification reporting requirement 5.6.10.a, the number of tubes plugged in each Steam Generator (S/G) shall be reported to the NRC within 15 days of the completion of the inspection or plugging effort. The inspection effort was completed on September 27, 2002. This letter provides the plugging results of the S/G inservice inspection performed during the Farley Unit 2 15th Refueling Outage.

Tube Category	S/G A	S/G B	S/G C
Tubes Removed from Service by Plugging	0	0	0

There are no NRC commitments associated with this letter.

If there are any questions, please advise.

Respectfully submitted,


J. B. Beasley, Jr.

WAS/sdl:u2sgplugging2002.doc

ADD1

Page 2

U. S. Nuclear Regulatory Commission

cc: Southern Nuclear Operating Company
Mr. D. E. Grissette, General Manager – Farley

U. S. Nuclear Regulatory Commission, Washington, D. C.
Mr. F. Rinaldi, Licensing Project Manager – Farley

U. S. Nuclear Regulatory Commission, Region II
Mr. L. A. Reyes, Regional Administrator
Mr. T. P. Johnson, Senior Resident Inspector – Farley